

Surface Water Monitoring Results (Event Based Only)

Location	Frequency	Source	Lower Limit	Upper Limit	Unit	Description	Event Date													
Licensed Discharge Point 1	Each Discharge Event	EPL Section L2	6.5	8.5	pH	pH	Result													
							Pass / Fail													
			-	50	mg/L	Suspended Solids	Result													
							Pass / Fail													
			-	NV	V = Visable or NV = None Visable	Total Oil & Grease	Result													
							Pass / Fail													
Licensed Discharge Point 2	Each Discharge Event	EPL Section L2	6.5	8.5	pH	pH	Result													
							Pass / Fail													
			-	50	mg/L	Suspended Solids	Result													
							Pass / Fail													
			-	NV	V = Visable or NV = None Visable	Total Oil & Grease	Result													
							Pass / Fail													

Comments regarding deposition monitoring outcomes	
Comment 1:	18th November 2022 - Precoat oil spill - sampled to confirm no oil leaving the site
Comment 2:	No discharge events means that surface water monitoring has not been triggered after 20th April 2023
Comment 3:	
Comment 4:	
Comment 5:	
Comment 6:	
Comment 7:	
Comment 8:	

